SUOMEN STANDARDISOIMISLIITTO **SFS-EN ISO / IEC 17050-1**
FINNISH STANDARDS ASSOCIATION SFS

Declaration of conformity

1. No	011220-EN

2. Issuers name and address	Meltex Oy Plastics
	Puuppolantie 111
	40270 Palokka / Finland

3. Object of the declaration	Meltex single wall cable protection pipes with and without pull wire
	Ring stiffness clas: B
	Pipe size Ø: 50 mm
	Material PVC.
	Production facility: Jyväskylä

4. The objects of the declaration described above is in conformity with the requirements of the following documents:

Document	Title	Edition / date of issue
Standard	SFS 5608	1990-02-19 3. edition
Standard	SFS 5211	2002-06-28 2.painos

5. Additional information	*SFS 5608. Maahan asennettavat kaapelinsuojukset ja varoitusnauhat.*
	SFS 5211. Muoviputket PVC-salaojaputkijärjestelmä peltosalaojitukseen.
	Cable ducting pipes are classed based on ring stiffness as strength,
	in class C (SN ≥ 4kN/m²), B (SN ≥ 8kN/m²) and A (SN ≥ 16kN/m²) in
	accordance with Finnish standard 5608.
	PVC cable protective pipes fulfill class B requirements.
	Meltex single wall PVC cable protection pipes are manufactured in
	accordance with standard SFS 5211 and meet the mechanical
	requirements for pipes set by standards SFS 5211 and SFS 5608.
	PVC material properties
	• K-value ~ 67
	• Density ~ 585 kg/m³
	• Viscosity number 105–115 ml/g

Signed on behalf of the issuer	Palokka 16.12.2020
	Jaakko Valkonen, Quality and development manager
	